



CITY OF VENICE FIRE DEPARTMENT

200 Grove Street N., Venice, Florida 34285
Phone: 941-480-3030, Fax: 941-480-3224
www.venicegov.com


Fire Chief Shawn Carvey

Based upon the requirements of the Florida Fire Prevention Code and Code of Federal Regulations Title 14 Subchapter C-Aircraft the following approved items may be stored in the airplane hangars at Venice Airport.

1. **Fueled aircraft.** This includes the associated communication, navigation and safety equipment stored in the aircraft.
2. **Aircraft engine oil:** Oil must be in sealed containers (up to two cases).
3. **Tow bar:** A powered tow bar would be permissible only if the equipment is listed for use as an airplane tow bar and it meets the requirements of NFPA 70 Article 513.
4. **Ladders:** The maximum limit is two.
5. **Open metal shelves:** Shelving must meet the requirements of NFPA 70 Article 480.
6. **Aircraft maintenance tools:** CFR 14 C 43.3 limits the owner to preventive maintenance operations that are "simple or minor preservation operations" such as adding or changing engine oil.
7. **Aircraft battery charger:** The equipment must be listed for use and operated in compliance with NFPA 70 513.10.
8. **Aircraft cleaning materials:** All cleaning material and operations must meet the requirements of NFPA 410 Chapter 5 and Chapter 7.
9. **Air Compressor:** The equipment must be listed for use and meet the requirements of NFPA 70 513.1.
10. **Lessee's vehicle:** It is a reasonable accommodation to allow the pilot the opportunity to store the vehicle used to arrive at the hangar inside the empty hangar while the aircraft is in use. This should not be construed as allowing the storage of any other vehicle such as an additional automobile, boat, motorcycle, snowmobile, Jet Ski, lawn tractor, aircraft or parts of the same in the hangar at any time.

The following specified items may be allowed but must meet certain rigid criteria for use in aircraft hangars.

1. Small electrical appliances shall meet the requirements of NFPA 70 article 513.10 (E) Portable Equipment.
2. Cords shall comply with NFPA 70 article 513.10 (C) 3.


Shawn Carvey
Fire Chief
01/26/16